



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/11/2025

Area: CHP

Equipment	Job
VS1,VF1	PPM was done
SCR 5	LT burnt motor coupling removed
SCR 4	PCRD cable winding done
All yard	HT coupler space heaters inspection was done
CM 18	One tube fixture and 2nos 30W LED lamps provided
CM 18	Room cleaning done
CC 201,222,223	Belt Scale maintenance was done
SCR 10	PCRD OT kept in ckt
SCR 9	Instrumentation sensors maintenance was done
CC 104,SCR 9	PPM was done