



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/02/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-5A	Reported no operations taking place	Control not made on by operator	09:10:00	09:25:00	Not an electrical delay
2	OHP	CO-76R	Reported tripped	OLR acted.Reset done	10:10:00	10:20:00	
3	OHP	CO-67	Reported tripped	OLR acted.Reset done	12:50:00	13:00:00	
4	OHP	BRC on CO-31	Reported LT not taking place	PCRD tension acted.Released and tested okay	13:45:00	13:55:00	
5	CHP	Cc-51	MPD tripped	Reset done(2 times)	06:40:00	11:50:00	
6	CHP	CC-117	Reported tripped	OLR acted.Reset done	12:20:00	12:25:00	
7	CHP	Cc-34 SCR-1	B/C position gvm side not coming	Sensor problem.Bypassed and given clearance	10:30:00	10:45:00	Sensor to be changed