



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/08/2025

Area: WT

Equipment	Job
OP 4	D2 bypassed due to Mech. problem, only four drives in circuit, informed to Operation
OT 3 series	Running Inspection done
EOT Crane (C)	Panel and motor side blowing and ppm done, 2C1 fixed contacts replaced
OP 2 and 4	After rake maintenance done
AF 5 and 6	Iron stair case side Lighting improved, one tube replaced