



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset it done	22:35:00	22:40:00	3 times
2	OHP	CO 29	OLR acted	reset	00:00:00	00:15:00	
3	OHP	CO 26	OLR acted	reset	00:00:00	00:15:00	
4	OHP	CO 34	OLR acted	reset	04:10:00	04:15:00	
5	OHP	CO 6a	brs not resetting, sensor problem	sensor adjusted properly	22:35:00	22:50:00	
6	OHP	CO 14 A	brs not resetting, reset button stucked up	reset button released	23:30:00	23:45:00	
7	OHP	BRC 32	B/C trips in OLR	reset	05:00:00	05:15:00	
8	CHP	CC 131	OLR acted	reset	03:15:00	03:20:00	
9	CHP	CC 52	ZSS acted, overload	clear load in local	01:45:00	01:50:00	
10	CHP	CC 112 SCR 8	BC not running, BSS acted	released it	22:25:00	22:40:00	
11	CHP	CC 32 SCR5	LT not working, under tension acted, pcrd guide problem	tension released informed mech	23:45:00	00:07:00	
12	CHP	CC 33 SCR4	LT not working inn remote mode, drive trips in SCF3 fault, in local LT ok, K1 relay not healthy	K! relay high given than remove after that ok	23:50:00	00:30:00	
13	CHP	CC 32	ZSS acted electrical all ok, belt tension problem	informed mech incharge	02:00:00	02:15:00	
14	CHP	CC 34 SCR 2	LT not taking place, vfd trips in ovrload	reset it done	02:00:00	02:15:00	
15	CHP	CC 105 scr 10	LUFF up not working, BC deck sheet full jamming	inform operation and mech, manually luffing up done than ok	03:40:00	04:10:00	
16	CHP	CC 125	OLR acted	reset it	04:55:00	05:05:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC 107	ZSS acted, belt full load condition, belt slow movement	informed operation incharge	05:00:00	05:20:00	