



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/09/2025

Area: WT

Equipment	Job
MIS	2 nos hand lamps provided @ OC 1A and OAF
CP 3	Trolley line checked and found insulator (2nos) puncture @ col no 17 bottom ,rectified
OP 10	Trolley line inspection done ,bus bar adjustment done @ col no 7,27,74 and 97
OC 1A level	35 W LED bulbs ,5 nos installed @ cc 4 side
LC 10B	area lighting improved (5nos LED tubes replaced)
LC 10 B	Faulty breakers 2 nos rectified and kept in service
MIS	OT 5 faulty drive blowing and checking done,not yet rectified
OP 3 and 5	After rake maintenance done