



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/01/2026

Area: WT

Equipment	Job
OP 2,4 and 6	After rake maintenance done
OP 6	C type Section Isolators ,2 nos maintenance done(col no 53 and 46)
OP 5	Anti collision device and timer "ST1" replaced and tested ,OK
OT 1 serise	Motor side ppm done
OAF1A	circuit checked, found no connection in Inch reverse PB (to be checked further)
OAF level	Lighting, 200W LED installed
OC1A	Circuit checked,fond Q1(MCCB) "NO" contact in bypass(to be checked further)
OC1A level	lighting rectified 50 W LED replaced