



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/12/2025

Area: IOSA

Equipment	Job
OC-27A	CONVEYOR STOPPING ON ZSS FAULT. CHECKED THE PROBE AND MUDULE. BELT NOT ROTATING DUE TO MATERIAL JAMMING.
OJH-8A	MAINTENANCE DONE ON SLDB AND MCBDB. DEFECTS RECTIFIED.
OC-23A	LIGHTING CIRCUIT RECTIFICATION IS IN PROGRESS. LIGHTING CIRCUIT RECTIFIED UPTO IDLER-400. SUFFICIENT LIGHTING ARRANGED.
MISL	MOTOR VIBRATION TAKEN FOR CONVEYORS OC-2A, OC-3A, OC-19A AND OC-21A. VALUES RECORDED.
OC-11A	PPM DONE ON MOTOR AND FIELD DEVICES .