



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 3	motor not running,FB coming,o/g all HT fuse blown	HT fuse replaced,given clearance	09:00:00	10:00:00	
2	OHP	TBS on CO 21	Left luff not working,olr acted	reset	10:55:00	11:05:00	
3	OHP	CO 113(B)	OLr acted	reset	13:00:00	13:10:00	
4	CHP	CC 216	mpd tripped	reset	10:05:00	10:10:00	
5	CHP	CC 108	olr acted	reset	12:35:00	12:40:00	
6	CHP	C 51	mpd acted 19 times	reset	07:00:00	07:05:00	
7	CHP	CC 51	OLR acted	reset	08:00:00	08:05:00	3 times