



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/08/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-11 (C/D)	NOT moving.CHECKED MPCB TRIP	MADE ON THAN OK	15:20:00	15:30:00	
2	OHP	CO-29	OLR ACTED	RESET DONE	14:40:00	14:50:00	
3	OHP	BRC ON CO -33M	REPORTED B/C NOT RUNNING CHECKED CONTROL MCB TRIP	MCB MADE ON THAN OK	17:20:00	17:40:00	
4	OHP	CO-87	REPORTED RED OLR ACTED	OLR RESET	18:40:00	18:50:00	
5	OHP	CO-35	STOPPING ON ZSS CHECKED ZSS PROBE WIRE GOT CUT	ZSS PROBE CABLE JOINT DONE THAN OK	19:20:00	19:40:00	
6	OHP	BRC ON CO-28	B/C NOT RUNNING OLR ACTED	OLR RESET	20:05:00	20:20:00	
7	CHP	CC-33 SCR-4	LT NOT TAKING PLACE CHECKED DRIVE TRIP SCF-3 FAULT	RESET	15:15:00	15:30:00	
8	CHP	CC-54	Reported not healthy	OLR acted.reset done(5 times)	18:00:00	18:45:00	
9	CHP	CC-51	Reported not healthy	MPD tripped on overload. Reset done	19:30:00 20:05:00	19:35:00 20:10:00	
10	CHP	CC-26 FG	Reported not moving	MPCB tripped.made on	15:40:00	15:50:00	
11	WT	CC-2 (C/D)	NOT TAKING PLACE OLR ACTED (2TIMES)	RESET	15:30:00	15:40:00	
12	IOSA	NEW WOBR	Reported LT not taking place.	Checked and found I/C Breaker tripped and not making on.Fire alarm bit bypassed at I/O rack and made on. M6 thruster brake made loose and LT tested okay	17:30:00	18:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/08/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	IOSA	OC-13A	BSS acted and control mcb tripped	Belt sway cable got cut. field wire removed and bypassed at PLC panel	15:25:00	16:00:00	Due to JCB machine working for jungle cleaning