



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/04/2025

Area: WT

Equipment	Job
	general inspection done, OP 2/D3 bed found uneven, informed to Mech.
EOT Crane(C)	panel side ppm done
CP 4	panel side ppm done
	parking zone panel maintenance done
	panel maintenance done for OP 1 to OP 6
	after rake maintenance done

OP 1 to 5 & CP 1 to 4

CP 2,3,4 & OP 1 to 6

LC 2A & 2B

OP 1,6,7 & 8