



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2025

Shift: A

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co-24	LT NOT WORKING IN REMOTE	DUE TO RECLAIMER HEIGHT	06:20:00	06:30:00	
2	OHP	CO-26 WOBR	SLEW NOT WORKING	DRIVE TRIPPING ON E00 FAULT ... RESET DONE	07:20:00	07:35:00	
3	OHP	CO-6A WOBR	PCRD PROBLEM FROM C SHIFT	MPCB CHANGED ... AND TESTED	06:00:00	07:30:00	
4	OHP	CO-34 BRC	LT NOT WORKING	BREAK MPCB TRIPPED MADE OFF AND CONTROL CONTACT BYPASSED	07:30:00 09:00:00	07:50:00 09:15:00	
5	OHP	CO-31 BRC	LT NOT MOVING	DRIVE TRIPPED DUE TO TRACK JAMMING ... RESET DONE	09:10:00	09:30:00	
6	OHP	RSCO-9A	B/D TRIPPED ON OLR	RESET DONE	13:30:00	13:40:00	
7	OHP	CR-1	TRIPPED DUE TO JAMMING	RESET DONE	07:50:00	08:00:00	
8	OHP	BRC ON CO-31	BC NOT RUNNING	OLR ACTED RESET DONE	13:30:00	13:50:00	
9	CHP	CC-131	STOPRD ON PULL CORD	BYPASSED	07:20:00	07:45:00	KEPT IN CKT AT 10:00
10	CHP	CC-54	TRIPPED ON OLR	RESET DONE (4 TIMES)	09:20:00	10:30:00	
11	CHP	CC-29 TT	TRIPPED	RESET DONE	09:50:00	10:00:00	
12	CHP	CC-33 SCR-4	SLEW NOT WORKING	LIMIT ACTED DUE TO JAMMING	06:55:00	07:30:00	
13	CHP	CC-39 SCR-7	position l/s problem	gvm side given in io rack	07:20:00	07:30:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	cc-35 scr-2	SIGNAL PROBLEM	WORK GOING ON	11:30:00	14:00:00	
15	CHP	CC-32 SCR-5	BC NOT WORKING	ZSS CAGE STUCK ...MADE FREE	13:45:00	14:00:00	
16	CHP	CC-36 SCR-1	SLEW NOT WORKING	MECH BREAKDOWN .. INFORMED OPERATION	13:30:00	13:45:00	