



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	07:30:00 10:10:00	07:40:00 10:20:00	
2	OHP	RSCO-10A	REPORTED STOPPING IN ZSS FOUND PROBE CHECK NUT LOOSE	PROBE CHECK NUT TIGHT THAN OK	09:50:00	10:00:00	
3	OHP	BRC ON CO-30	B/C TRIPPED ON OLR	RESET DONE	09:15:00	09:25:00	
4	OHP	CO-58	REPORTED STOPPING ON ZSS PROBE DIRECT	ZSS PROBE REPLACED WITH NEW PROBE THAN OK	12:45:00	13:40:00	
5	CHP	CC-29 TO CC-31	POSITION INDICATION NOT SHOWING AT I/O RACK FIELD WIRE REMOVED CONDITION	FIELD WIRE CONNECTED THAN OK	06:50:00	07:00:00	
6	CHP	CC-54	OLR ACTED (4TIMES)	RESET DONE	07:00:00	12:00:00	
7	CHP	CC-117	OLR ACTED	RESET DONE	06:00:00	06:10:00	
8	CHP	CC-131	OLR ACTED	RESET DONE	11:40:00	11:45:00	
9	CHP	BC STREAM	REPORTED NOT HEALTHY FOUND LC-19 I/C-1 TRIP DUE TO EARTH FAULT	FAULT ISOLATED I/C CHARGED THAN OK	12:00:00	12:15:00	
10	CHP	CC-31 SCR-4	B/C NOT RUNNING FOUND SELECTION PROBLEM	SELECTOR SWITCH KEPT CORRECT POSITION THAN OK	06:40:00	06:50:00	
11	CHP	CC-33 SCR-5	PCRD CABLE FELL DOWN DUE TO SINGLE PHASE	OUT GOING CONNECTION TIGHT THAN CABLE LAYING WAS DONE	07:50:00	08:10:00	
12	CHP	CC-104 SCR-9	SLEW NOT WORKING FOUND RELAY STUCK UP	RELEASED THAN OK	08:05:00 09:40:00	08:15:00 09:55:00	
13	CHP	CC-112 SCR-8	SLEW NOT WORKING LIMIT ACTED DUE TO JAMMING	AFTER CLEANING MATERIAL LIMIT RELEASE THAN OK	09:20:00	09:30:00	