



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC-23	REPORTED STOPPING ON ZSS FOUND ZSS PROBE PROBLEM	ZSS PROBE REPLACED THAN OK	07:10:00	07:25:00	
2	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	08:00:00 10:25:00	08:05:00 10:30:00	
3	CHP	CC-108	TRIPPED ON OLR (2TIMES)	RESET DONE	10:00:00 12:10:00	10:05:00 12:15:00	
4	WT	OP-5	DRIVE-1 OLR ACTED	RESET DONE	12:05:00	12:15:00	