



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/08/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 29	LT not taking place due to overload acted M4	reset done	22:25:00	22:45:00	
2	OHP	CO 35	OLR acted	reset done	01:15:00	01:20:00	
3	OHP	CO 29	OLR acted	reset done	23:05:00	23:10:00	
4	OHP	WOBR on CO 25	BC not running	ZSS probe damaged , replaced	03:55:00	04:30:00	
5	OHP	CO 14B	OLR acted	reset done	02:45:00	02:55:00	
6	OHP	WOBR on CO 26	Slew drive tripped	reset done	23:30:00	23:45:00	
7	OHP	wobr on co 29	b/c not running,zssc age stuck due to stone	stone removed	05:55:00	06:10:00	
8	CHP	CC 112 , S 2	BC not running due to OLR acted	reset done	22:20:00	22:40:00	
9	CHP	CC 33 , SCR 4	LT end limit bypass request from operation	bypassed in IO rack	23:25:00	23:45:00	
10	CHP	CC 201	Not healthy due to pull chord acted	bypassed in TB	02:30:00	03:15:00	
11	CHP	CC 34 , SCR 2	LT not working due to overtension acted	released	03:30:00 04:10:00	03:50:00 04:25:00	
12	CHP	CC 48	BRS bypass request from operation	Bypassed . Again kept in circuit	01:30:00	02:25:00	
13	CHP	CC 7	Reported not healthy due to Incomer 2 tripped in LC 21	Bus coupler made on	22:10:00	22:40:00	Incomer 2 to be checked



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 51	MPD tripped ( 3 times) and feeding conveyor stopped	reset done	23:00:00	03:15:00	
15	CHP	CC 54	Tripped ( 5 times)	reset done	01:45:00	02:45:00	