



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC117	Motor trip due to over load	Reset done	16:30:00	16:50:00	
2	OHP	TT2	LT not working found MPCB trip	Reset done	19:30:00	19:40:00	
3	CHP	RG2 flap gate	Flap gate motor trip	Reset done	20:00:00	20:05:00	
4	CHP	CC54	Motor over load trip due to over load	Reset done	20:45:00	20:50:00	
5	CHP	CC31 Flap gate	Flap gate motor trip	Reset done	21:00:00	21:05:00	
6	CHP	CC51	ZSS acted found over load	Informed to operation and mechanical	16:00:00	16:01:00	
7	CHP	SCR10 on CC105	BC not running found MPR tripped fault EF	Reset done	14:25:00	14:35:00	
8	CHP	SCR5 on CC32	BC not running found Over load relay tripped	Reset done	14:55:00	15:05:00	
9	CHP	SCR4 on CC33	Slew not working XMD panel reset done	Reset done	15:20:00	15:40:00	
10	CHP	SCR7 on CC36	LT not working found OT limit acted and rev contactor struck	Limit released and contactor made free	15:40:00	16:15:00	
11	CHP	SCR1 on CC35	LT and slew not working found 30 degree acted and LT drive tripped	LT drive reset done and Reset done	16:40:00	17:00:00	
12	CHP	CC36	BRS not healthy sensor receiver fault	new sensor fixed and bypass removed	18:40:00	19:00:00	
13	CHP	SCR3 on CC38	Mode not changing found signal missing radio modem ping done	Machine LT done toward DE side then ok	19:30:00	19:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Shift: B

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	SCR7 on CC36	LT not moving found Over tension limit acted	Over tension limit released then ok	19:40:00	19:55:00	
15	CHP	CC202	Over load trip	Reset done	19:55:00	20:00:00	