



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/09/2025

Area: WT

Equipment	Job
OT 2 series	panel and motor side ppm done
EOT Crane(O)	Aux Hoist hook got stuck up ,released it
EOT Crane(O)	Main hoist circuit checked,2C1 contactor aux bock replaced,Y phase (I/C) lug and connector replaced