



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/06/2025

Area: CHP

| Equipment | Job |
|---|--|
| CC-52,CC-53,CC-54,CC-55,CC-56,CC-57,CC-58 | ppm done |
| CC-219 lighting | Lighting faults rectification done |
| CC-41 | panel and CJB side cable connections done. CJD and Emergency push button circuit separated. Feedback checked |
| SCR-1 | PLC input and output cards tightness done |
| SCR-3 | Luffing circuit checking done |
| SCR-9 | New volktek media converter kept in line for upper house to lower house OFC communication |
| CC-41,CC-108 | ppm done |