



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|-------------------------------|-------------------------|----------|----------|---------|
| 1 | OHP | brc on co 34 | B/C OLR ACTED | RESET | 00:00:00 | 00:15:00 | |
| 2 | OHP | CO 29 | OLR ACTED(2TIMES) | RESET | 01:00:00 | 01:15:00 | |
| 3 | OHP | CO 35 | OLR ACTED | RESET | 03:00:00 | 03:55:00 | 2 TIMES |
| 4 | OHP | CO 26 | OLr acted | reset | 04:15:00 | 04:30:00 | |
| 5 | OHP | CO 15 | OLR acted | reset | 23:30:00 | 23:45:00 | |
| 6 | CHP | CC 32 SCR 5 | LT not working,OT acted | released OT | 23:17:00 | 23:28:00 | |
| 7 | CHP | CC 32 | OLR acted | reset | 03:25:00 | 03:30:00 | |
| 8 | CHP | CC 35 SCR 2 | BC not running,signal missing | signal came and healthy | 01:20:00 | 01:25:00 | |
| 9 | CHP | cc 117 | olr acted | reset | 22:55:00 | 23:04:00 | |
| 10 | CHP | cc 54 | olr acted | reset | 01:50:00 | 01:55:00 | 3 times |
| 11 | CHP | cc 51 | OLR ACTED | RESET | 23:50:00 | 23:55:00 | |
| 12 | CHP | CC 51 | belt sway acted | reset it | 01:15:00 | 01:26:00 | |
| 13 | CHP | CC 131 | olr acted | reset | 01:30:00 | 01:35:00 | 3 times |