



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/08/2025

Area: IOSA

Equipment	Job
OC-19A	LIGHTING CIRCUIT RECTIFIED AND SUFFICIENT LIGHTING ARRANGED IN TUNNEL AT CHUTE AREAS.
WOBR- FLS	POWER CABLES OF DAMAGED LUBRICATION PANEL REMOVED AND SHIFTED TO ELECTRICAL SHED.
WOBR L and T	HYDRAULIC RAIL CLAMP LIMIT SWITCHES AND PRESSURE SWITCHES FEEDBACK NOT COMING. CLEARANCE GIVEN AFTER RECTIFICATION AND TRIAL RUN.
WOBR-L and T	LUFFING IS NOT TAKING PLACE. RIGHT CYLINDER ROD HI PRESSURE TRIP ACTED. AFTER RECTIFICATION TRIAL RUN DONE AND GIVEN CLEARANCE.
OC-7A	PPM DONE ON FIELD DEVICES OF ZONE-1 and 2