



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 07/07/2025

Area: IOSA

Equipment	Job
WOBR ( FLS)	MACHINE TRIAL RUN TAKEN AFTER MECH. JOB.
ZSS CAGE and MODULE	ZSS CAGE AND MODULE SETTING CHECKED FOR CONVEYORS OC-2A,3A,4A,5A,6A,7A,7B,7C,9A,11A,19A,21A,23A,25A,27A,29A,31A,33A,36A,37A.
MISC	HOUSE KEEPING DONE IN LC=2 GROUND FLOOR.
WOBR (FLS)	REMOVAL OF UNWANTED CABLE IS IN PROGRESS.
OC-15A	PPM DONE ON MOTOR.
WOBR ( L and T)	MACHINE TO OCR-2 COMMUNICATION MISSING SOME TIMES. MACHINE TO YARD CONVEYOR ZSS CAGE LOWERED AN GIVEN CLEARANCE AFTER CHECKING AND TRIAL RUN.