



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/11/2025

Area: WT

Equipment	Job
OP 4	Trolly line section Isolators maintenance done ,4 nos (col no90,83,76 and 70)
CP 1 to 4	General inspection done,found one lug cut in CP3/D5 motor T B,replaced it
OP 2,5 and 7	General inspection done @parking zone
OP 1,4 and 6	After rake maintenance done