



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/11/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment     | Problem  | Action               | From     | To       | Remarks |
|-------|------|---------------|--|----------------------|----------|----------|---------|
| 1     | OHP  | TBS on co 21  | Lt not working,brake problem                           | informed mechanical  | 14:50:00 | 15:10:00 |         |
| 2     | OHP  | BRC on Co 28  | LT not working,wrong complaint                         | informed operation   | 17:00:00 | 17:10:00 |         |
| 3     | OHP  | WOBR on co 26 | slew not working,drive tripped                         | reset                | 18:00:00 | 18:20:00 |         |
| 4     | OHP  | CO 29         | olr acted  | reset                | 17:35:00 | 17:45:00 |         |
| 5     | CHP  | CC 104 scr9   | slew not working,slew aux contact of OL relay problem  | aux contact replaced | 14:10:00 | 14:25:00 |         |
| 6     | CHP  | CC 125        | olr acted  | reset                | 17:35:00 | 17:45:00 |         |
| 7     | CHP  | CC 35 SCR3    | LT not working,drive tripped                           | reset                | 17:50:00 | 18:06:00 |         |
| 8     | CHP  | CC 34 SCr 1   | LT not working,drive tripped                           | reset                | 19:10:00 | 19:30:00 |         |
| 9     | CHP  | CC 105        | brs acted,operation told not resetting,wrong complaint | BRS easily got reset | 20:00:00 | 20:10:00 |         |
| 10    | CHP  | CC 117        | motor trips due to overload                            | reset                | 19:40:00 | 20:00:00 |         |
| 11    | IOSA | BRC           | LT not working,LT limit switch acted due to rod        | rod removed          | 20:15:00 | 20:30:00 |         |
| 12    | IOSA | OC 15 A       | ZSS acted ,stone stucked in cage                       | stone removed        | 20:59:00 | 21:10:00 |         |