



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/09/2025

Area: CHP

Equipment	Job
LBDS 1	4 nos tube fixtures replaced
LC 17	Rooms cleaning done
SCR 8	LUFF pump contactor replaced
CC 38	TUL modification done
S1,S3	Stacking restriction angle limits tested
CC 38,104,SCR 6,9,CC 116,117,117TT	PPM was done
CC 38,39,40,41,43,47,50,SCR 3,6,7	Running inspection was done