



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/01/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	07:00:00 08:30:00 11:20:00	07:10:00 08:35:00 11:30:00	
2	OHP	co 13 b/d	tripped on mpcb due to jamming	mpcb made on	12:00:00	12:05:00	
3	OHP	cc 54	tripped on olr	reset done 2 times	07:35:00 12:20:00	07:40:00 12:40:00	
4	CHP	cc 35	reported red/olr acted/reset	checked and found motor got burnt	09:30:00	09:40:00	job is going on
5	CHP	cc 51	zss acting due to over material on the conv.	conv.not taking place in local/inform to operation	12:45:00	13:00:00	
6	CHP	cc 33	tripped on olr 5 times	reset done	11:20:00	12:20:00	
7	WT	op 6	D5 tripped on olr while coupling	reset done	07:25:00	07:35:00	
8	WT	op5	D2 tripped on olr while coupling	reset done	12:35:00	12:40:00	