



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/11/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--------------------------------|---|----------------------------------|----------------------------------|--------------------------------------|
| 1 | OHP | BRC on CO-28 | Reported LT not working | checked and found drive tripped on earth fault.M4 removed and tested okay | 19:40:00 | 19:54:00 | M4 motor and cable to be checked |
| 2 | CHP | CC-23 | Reported tripping | checked and found motor power cable got entangled with post and insulation damaged.Insulated properly and tested okay | 15:00:00 | 15:30:00 | |
| 3 | CHP | CC130 TIS | Reported not healthy | Checked and found EPB acted.Released and tested okay | 14:30:00 | 14:40:00 | |
| 4 | CHP | CC-132 | Reported P/C acted | P/C switch reset done and tested okay | 18:00:00 | 18:15:00 | |
| 5 | CHP | CC-51 | Reported BSS acted | Checked and found fuse burnt.Fuse replaced and BSS released and tested okay | 15:15:00 | 15:30:00 | |
| 6 | CHP | CC104 SCR-9 | Reported Slew not taking place | OLR acted.Reset done | 14:35:00 | 14:45:00 | |
| 7 | CHP | CC 39 scr-2 | LT not working | PCRD overtension acted.Released and tested okay | 17:20:00 | 17:30:00 | |
| 8 | CHP | Cc 105 SCR-10 | Reported LT not taking place | Checked and found PCRD guide in full jamming condition | 21:30:00 | 21:45:00 | Informed to operation and mechanical |
| 9 | WT | OT-5 | Reported tripped | Drive tripped due to jamming.(3 times).Reset done | 14:15:00 19:35:00 19:50:00 | 14:20:00 19:40:00 19:55:00 | |