



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/11/2025

Area: IOSA

Equipment	Job
BATTERY CHARGER	REMOVED FROM BASE AND SHIFTED UPTO DOOR FOR LIFTING and SHIFTING.
OC-11A	ZSS CAGE AND MODULE FIXED, CABLE ROUTED , CONNECTED AND TAKEN IN LINE.
HMT-3 and 4	JUNGLE CUTTING DONE AROUND HIGH MAST TOWER LIGHTING
BRC	CT END LIMIT ACTUATOR FABRICATION WORK COMPLETED.
TBS	RIGHT BOOM AND LEFT BOOM LUFFING EM BRAKES CHECKED.
TBS	RIGHT BOOM HOIST BRAKE THRUSTER BRAKE REMOVED AND SPARE THRUSTER CHECKED AND SHIFTED TO TBS. TO BE FIXED.
OC-16A	PPM DONE ON FIELD DEVICES