



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/08/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	reset done	08:20:00	08:25:00	
2	OHP	CO 35	OLR acted	reset done	08:35:00	08:40:00	
3	OHP	WOBR on CO 6A	BW not rotating due to CP 1 acted	Informed to operation	09:00:00	09:15:00	
4	OHP	TT 3 on CO 28	Position signal problem	male plug pins loose , tightened then ok	10:30:00	10:45:00	
5	CHP	CC 51	MPD tripped (3 times)	reset done	08:50:00	13:00:00	
6	WT	OC 1A	OLR acted	reset done	10:00:00	10:10:00	