



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	23:20:00	23:30:00	
2	OHP	CO-22 TBS	LBC ZSS CAGE STONE STUCK	STONE REMOVED	00:10:00	00:30:00	
3	OHP	BRC ON CO-34	bc direction REVERS IN OPR REQUEST AND FOUND COUPLING FAILED	INFORMED MECH	22:30:00	22:50:00	
4	OHP	VS-4A	TRIPPED ON OLR	RESET DONE	02:50:00	03:05:00	
5	OHP	CO-29	TRIPPED ON OLR	RESET DONE	01:00:00	01:15:00	
6	OHP	BPC-2	ZSS CAGE PROBLEM .. ROD MISSING	ROD FIXED	22:15:00	22:30:00	
7	CHP	CC-35 S-2	LT NOT WORKING M2 TRIPPED	RESET DONE	00:40:00	01:00:00	
8	CHP	CC-40 SCR-3	SIGNAL MISSING	LT DONE THEN OK	00:00:00	00:30:00	
9	CHP	CC-40 SCR-3	LT STOPPING IN BETWEEN	LT HEALTHY RELAY DROPPING SOME TIMES CONTROL CIRCUIT CHECKED .. NEUTRAL MISSING TERMINAL TIGHTENED	00:45:00	01:10:00	
10	CHP	CC-35 S-2	SLEW NOT WORKING	SLEW LIMIT NOT HEALTHY ... BYPASSED	23:00:00	23:30:00	TO BE CHECKED
11	CHP	CC-125	TRIPPED ON OLR	RESET DONE	02:05:00	02:15:00	
12	CHP	CC-51	MPD TRIPPED	RESET DONE (4 TIMES)	22:50:00	01:00:00	
13	WT	OP-5	NOT MOVING	CONTROL MCB TRIPPED IN PUSHED .. RESET	23:10:00	23:20:00	
14	WT	CP-1	NOT MOVING	BREAKER TRIPPED ... MADE ON	01:35:00	01:45:00	
15	WT	CP-3	NOT MOVING D3 OLR ACTED	RESET	02:45:00	03:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	CC-3	TRIPPED	RESET	03:15:00 03:30:00	03:20:00 03:35:00	
17	WT	OP-3	NOT MOVING .. PARKING ZONE CONTACTOR NOT ON	JUMPER GIVEN IN BUS BAR ... PUSHER CAME FWD	05:00:00	06:00:00	
18	IOSA	L and T WOBR	LUFF NOT WORKING	RHS BAR PRESSURE HIGH ... INFORMED MECH AND OPERATION	04:00:00	04:30:00	