



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-21	Yard ZSS problem	Probe check nut loose.Tightened and tested okay	14:00:00	14:11:00	
2	OHP	TBS on CO-19	Right luff not working	Wrong complaint	14:50:00	15:00:00	
3	OHP	CO-84	Reported tripped	OLR acted.Reset done	16:11:00	16:15:00	
4	OHP	BRC on CO-30	B/C not running	Yard ZSS module wire loose. Tightened and tested okay	18:00:00	18:40:00	
5	OHP	TBS on CO-22	chute sensor malfunctioning	Kept in Bypass	19:45:00	20:00:00	
6	CHP	Cc-28	Reported tripped	OLR acted.Reset done	17:30:00	17:40:00	
7	CHP	CC-51	MPD acted	Reset done(8 times)	15:10:00	21:30:00	
8	CHP	CC-51	Tripped	OLR acted.Reset done	17:50:00	17:55:00	
9	CHP	CC-219	ZSS acting	Cage stuck.Cage replaced	18:15:00	18:35:00	
10	CHP	CC-213	B/C not working	Material selection not given by CPP.Bypassed in program	19:00:00	19:30:00	
11	CHP	CC-108	Reported tripped	OLR acted.Reset done	20:55:00	21:00:00	
12	CHP	CC-213	Chute sensor acting	Acting due to moisture.Bypassed at module.	20:45:00	20:55:00	
13	WT	OP-8	Communication problem	Module power recycled	14:00:00	14:10:00	
14	WT	OP-2	Reported tripped	D1,D5 tripped.Reset done	14:30:00	14:45:00	
15	WT	Af-2A	E-stop PB not releasing	Wrong complaint	15:00:00	15:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OP-4	Reported not moving	Top pad fallen. Welding done and pad kept in place and tested okay	19:30:00	21:00:00	