



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/08/2025

Area: WT

Equipment	Job
OT 5	LS 1 and 2 Limits cables removed due to Tippler breakdown and 'HIGH' wire removed.
OT 4	Hopper area lighting distributed and 2*400W SV fitting installed , control JB provided
OP 4	D2 motor removed for mechanical job
OP 1,4 and 7	After rake maintenance done