



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/02/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 33m	olr acted	reset	06:55:00	07:05:00	
2	OHP	wobr on co 29	b/w olr acted	reset	08:00:00	08:10:00	
3	OHP	CO 2	brs acted	small hole in the belt,informed operation and reset brs	11:30:00	11:45:00	
4	OHP	BRC on Co 32	LT not taking place,OT acted	OT released	08:40:00	08:55:00	
5	OHP	RSCO 10 A	no power,l/c 1 tripped in 1-141LC3 in UV fault	I/C made on	12:40:00	12:50:00	
6	OHP	brc on co 32	LT not working m4 olr acted	reset	13:40:00	13:50:00	
7	OHP	brc on CO 31	b/w 2 not running,olr acted	reset	13:45:00	13:55:00	
8	CHP	CC 32 SCr 5	all drive not working,emergency PB contact problem	contact replaced	10:15:00	10:30:00	
9	CHP	CC 107	BRS acted frequently	sensor cleaned than ok	11:00:00	11:15:00	
10	CHP	CC 54	tripped 9 times due to olr	reset	07:00:00	07:05:00	
11	CHP	C 51	mPD tripped	reset	06:35:00	06:40:00	3 times
12	CHP	CC 131	olr atced	reset	13:05:00	13:10:00	
13	WT	OP 2	no movement,d1 and d4 olr acted @coupling	reset	13:35:00	13:50:00	