



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 34	LT PCRD O/T ACTED DUE TO GUIDE PROBLEM	PCRD LOOP GIVEN AND DRUM ARRESTED	19:00:00	19:20:00	
2	OHP	CO 10A	OLR ACTED	RESET	18:40:00	18:50:00	
3	CHP	CC 39	BSS ACTED DUE TO LEVER STUCK	MADE IT FREE	14:30:00	15:00:00	
4	CHP	CC 201	OLR ACTED	RESET	15:20:00	15:30:00	
5	CHP	SCR 7 ON CC 37	SLEW BREAK FAIL	RESET	16:10:00	16:30:00	
6	CHP	SCR 8 ON CC 112	SLEW 30 LIMIT ACTED	RELEASED	16:30:00	16:50:00	
7	CHP	SCR 10 ON CC 105	SLEW PUMP OLR ACTED	RESET	17:20:00	17:30:00	
8	CHP	CC 223	INCOMER 2 TRIPPED IN LC6	MADE IT ON	18:55:00	19:10:00	
9	WT	OP1,2,3,4,5,6 NOT MOVING	COMMUNICATION PROBLEM	POWER RECYCLED IN LC1	20:55:00	21:10:00	