



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	olr acted	reset	02:45:00	02:55:00	
2	OHP	CO 29	OLr acted	reset	05:10:00	05:15:00	
3	OHP	CO 34	olr acted	reset	01:00:00	01:10:00	
4	CHP	CC 52	vfd trips in ot, not reset	changed to DOL	00:00:00	00:15:00	
5	CHP	CC 51	mpd trips feeding conveyor	reset	02:10:00	02:15:00	