



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/12/2025

Area: WT

Equipment	Job
MIS	COMBIUM make set of modem/Antenna installed @ O7 and OT 4 found communication OK
MIS	Air Compressors 1 and 2,panels blowing done and Comp 2(NEW) kept on running
MIS	OP 4/D2 removed motor @ maintenance zone , meggaring done found OK
LC 10 A	Space Heaters supply checked found available in both T1 and T2 .
LC2A	cable laid and supply provided foe space heater with MCB control in T1 room
LC 2A and 10A	Feeder 2 ,racked In and charged
OP 1,4,6 and 8	After rake maintenance done