



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/07/2025

Area: CHP

Equipment	Job
CC 116	Spare motor shifted to mixture building and coupling removed
CC 126 Stair case	Ckt problem rectified and improved lighting
SCR 9	Slew panel MCCB replaced with Siemens 160A MCCB and trial run was taken
CC 31,34	Drive chute sensor modification was done
CC 31 , R1	PPM was done
CC 111,126,SCR 1,5,8,S 3	Running inspection was done