



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/08/2025

Area: CHP

Equipment	Job
CC 222	Belt weigher calibration done
CC 222/223	22nos 70W defective fixtures removed and 12 fixtures made ready for use
SCR 3	Boom conveyor electronic OLR replaced and tested. Slew/Luff instrumentation switches maintenance done and covered .
S 2	Stacking restriction angle limits welded and kept inckt