



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2025

Shift: A

Incharge(s): V Balaji Naik,G Eswara Rao

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|--|----------|----------|---------|
| 1 | OHP | brc on co 28 | bw s are not running/ bw 1 mccb tripped | mccb made on | 06:40:00 | 07:00:00 | |
| 2 | OHP | brc on co 28 | c t not taking place/chain got cut | inform to operation &mech.; | 09:00:00 | 09:20:00 | |
| 3 | OHP | co 35 | tripped on olr | reset done | 10:00:00 | 10:10:00 | |
| 4 | OHP | brc on co31 | bw s are not running/attended g shift for zss checking | zss kept in ckt. | 10:45:00 | 11:00:00 | |
| 5 | OHP | rsco 10a C/D | tripped on olr | reset done | 11:00:00 | 11:20:00 | |
| 6 | CHP | scr 5 on cc 32 | bc not running/mccb tripped due to jamming (head end side) | mccb made on | 11:50:00 | 12:00:00 | |
| 7 | CHP | scr 5 on cc32 | bc stopping inbetween/didnt found any elect.problem | inform to mech to check the fluid coupling oil | 12:10:00 | 12:20:00 | |
| 8 | CHP | CC 51A | TRIPPED ON OLR . | reset done | 07:45:00 | 07:50:00 | |
| 9 | CHP | SCR 4 on cc 33 | no drives running/wrong complaint | fault reset done | 06:35:00 | 06:45:00 | |
| 10 | CHP | scr 6 on cc40 | bc not running | power &control; off /on then ok | 11:00:00 | 11:15:00 | |
| 11 | CHP | SCR4 on CC33 | LT NOT WORKING DUE TO FULL TRACK JAMMING | Informed to operation | 13:30:00 | 13:40:00 | |
| 12 | IOSA | wobr FLS | lt speed changed for machine placement | kept in normal speed 10HZ | 09:10:00 | 09:45:00 | |