



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/06/2025

Area: OHP

Equipment	Job
CO-5,6,7,1A,JH-2	Lighting panel maintenance done
JH-3 to JH-4	Lighting done and rectification done
Day bin Compressor	Air Blaster phase fault rectification done
CO-49	Chute sensor earthing provided
CO-14A,14B,49	Hoist PPM done
WOBR ON CO-26	Brake panel shifting done and positioning and welding done
TBS-7 on CO-19	PPM done
CO-5A	PPM done
TBS-4 ON CO-5A	PPM done