



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 84	tripped on olr	reset 2times	09:30:00 10:50:00	09:40:00 11:00:00	
2	CHP	cc 51	tripped on olr	reset done 10times	07:00:00	13:40:00	feeding conv. stop
3	CHP	cc 45	tripped on olr	reset	08:30:00	08:35:00	
4	CHP	cc 50	brs acting	bypassed for ope. request	10:45:00	10:50:00	again kept in ckt
5	IOSA	brc on oc 15a	ct not taking place/	parameters changed/then ok	09:00:00	09:20:00	