



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/05/2025

Area: CHP

Equipment	Job
CC 25/26	Gallery Lighting improved
CC 47	BS switches control wiring completed
SCR 2	2 nos LT motors replaced and alignment was done
CC 8,14,18,23, 34,47,50,114,115, S 1	PPM was done