



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/10/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 63	MPCB TRIPPED	MADE IT ON	03:05:00	03:15:00	
2	OHP	CO 34	OLR ACTED	RESET	05:00:00 22:30:00 23:00:00	05:10:00 22:40:00 23:10:00	
3	OHP	CO 26	OLR ACTED	RESET	05:00:00	05:10:00	
4	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	01:45:00	03:00:00	3 TIMES
5	CHP	CC 54	OLR ACTED	RESET	02:20:00	03:00:00	5 TIMES
6	CHP	CC 113 A	OLR ACTED	RESET	05:35:00	05:45:00	
7	CHP	CC 26	F/G OLR ACTED	RESET	03:45:00	04:00:00	
8	CHP	SCR2 ON CC 34	SLEW DRIVE TRIPPED	RESET	01:35:00	01:50:00	
9	WT	OT1	DRIVE 2 TRIPPED ON PGF1 FAULT	RESET	23:50:00	23:55:00	
10	WT	OT2	DRIVE 2 TRIPPED ON PGF1	RESET	22:35:00	22:40:00	
11	IOSA	OC 7B	DMPR TRIPPED ON THERMAL OVERLOAD AND MASTER RELAY ACTED	RESET	01:30:00	02:20:00	