



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32 C/S CHP SIDE	MODULE TO I/O RACK CORE PROBLEM	BY PASSED IN I/O RACK	10:25:00	10:55:00	
2	CHP	CC 117	OLR ACTED	RESET	07:00:00 08:15:00	07:15:00 08:20:00	
3	CHP	CC 51A	OLR ACTED	RESET	07:05:00	07:10:00	
4	CHP	CC 54	OLR ACTED	RESET	09:40:00	10:30:00	4 TIMES
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	09:15:00	09:45:00	2 TIMES
6	WT	OP 2	D5 OLR ACTED	RESET	13:40:00	13:50:00	
7	WT	OT2	D2 TRIPPED ON PGF1 FAULT	RESET	13:00:00	13:05:00	