



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/06/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 21	Right BC stopping on ZSS	Material stucked in cage , removed	00:00:00	00:20:00	
2	OHP	CO 35	OLR acted	reset done	00:35:00	00:40:00	
3	OHP	WOBR on CO 6A	Pump not starting due to oil level low	Informed to mechanical and operation	03:00:00	03:15:00	
4	OHP	CO 33M , BRC	LT ABB drive tripping	Drive problem. Replacement work going on	01:30:00	06:00:00	
5	OHP	CO 7	Stopped in ZSS	Cable joint problem , probe cable joined properly	22:45:00	23:10:00	
6	CHP	CC 105 , SCR 10	No power reported	Incomer tripped. After charging , still BC not running in Rec mode . Then PLC recycled and ok	23:30:00	00:00:00	
7	CHP	CC 39 , SCR 7	Slew not working	Spider reset	23:45:00	00:00:00	
8	CHP	CC 36 , SCR 1	Signal missing	LT forward done	23:50:00	00:00:00	
9	CHP	CC 33 , SCR 4	BC Zero speed acted due to coal piece in cage	Removed then Zero speed healthy and BC running ok	03:35:00	03:50:00	
10	CHP	CC 33 , SCR 4	BW not running	Found oil level low, informed to mechanical	05:00:00	05:20:00	
11	CHP	CC 131	Tripped (5 times)	reset done	00:15:00	05:20:00	
12	CHP	RG 3	Flap gate not moving	Tripped , reset done	22:10:00	22:15:00	
13	WT	OP 8	Not moving in forward direction	LS 1 not healthy , bypassed in CJB	23:10:00	23:30:00	