



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/11/2025

Area: WT

Equipment	Job
OP 1	Panel and Motor side ppm done, D6 motor End cover bolt found missing ,provided
OP 8	Panel and Motor side ppm done
CT 1 and 2	Hopper lighting ,200W LED one in each, one @ out haul side provided
OP2,7,9 ,CP1 and 3	After rake maintenance done