



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/05/2025

Area: IOSA

Equipment	Job
MISC	OC-27A and 36A H/E and T/E CABLE TRAY WELDING DONE AND CABLE DRESSING DONE.
WOBR (L and T)	LT, BUCKET WHEEL and SLEW NOT WORKING . FOUND LT NOT TAKING PLACE DUE TO RAIL UNIT OIL LEVEL LOW.SLEW and BUCKET WHEEL FAULT IS OIL LEVEL LOW.
OC-11A	RADIO MODEM UNIT PANEL PPM DONE.
OC-29A	MOTOR AND FIELD DEVICES PPM DONE