



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-20	RBC CONTROL MCB TRIP	RESET DONE	06:30:00	06:40:00	
2	OHP	CR-3	REPORTED CR-3 NOT RUNNING CHECKED AND FOUND OIL FLOW NOT OK FAULT SHOW INFORMED TO MECHANICAL	OIL TOP UP THAN FAULT RESET DONE	07:30:00	07:40:00	
3	OHP	CO-35	OLR ACTED	RESET DONE	08:40:00	08:50:00	
4	OHP	BRC ON CO-30	LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED	12:15:00	12:25:00	
5	OHP	CO 84	REPORTED STOPPING ON PULL CHORD	PULL CHORD BYPASSED OPERATION REQUIREMENT	12:50:00	13:00:00	
6	OHP	RSCO-10A C/D	OLR ACTED	RESET DONE	11:00:00	11:10:00	
7	CHP	CC-51	MPD TRIP (12TIMES) FEEDING CONVEYOR	RESET DONE	08:00:00	12:00:00	
8	CHP	CC-52 TIS	OLR ACTED	RESET DONE	09:40:00	09:50:00	
9	CHP	CC-37 SCR-7	SLEW NOT WORKING FOUND OIL LEVEL LOW	INFORMED TO MECHANICAL	07:15:00	07:25:00	
10	CHP	CC-37 SCR-7	LT NOT WORKING PCRD O/T ACTED	RELEASED THAN OK	10:45:00	10:55:00	
11	CHP	CC-33 SCR-5	LT MOTER-2 MPCB TRIP	RESET DONE THAN LT OK	09:45:00	09:55:00	
12	CHP	CC-112 SCR-8	SLEW NOT WORKING FOUND SLEW LIMIT ACTED	LIMIT RELEASED THAN OK	11:20:00	12:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-33 SCR-5	B/C NOT RUNNING FOUND MPD TRIP	RESET DONE THAN OK	11:35:00	11:50:00	
14	WT	OT-3	NOT ROTATING DRIVE-1 ENCODER FAULT	RESET DONE	06:30:00	06:50:00	