



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2025

Area: CHP

Equipment	Job
CC-52,CC-130	ZSS program checked
CC-51	8 no's belt sway switches taken into line and kept into circuit
CC-39	Ground isolator canopy fixing done
S-2	motors blowing done
S-2	lighting rectification work done, slew left limit replacement done, slew motors canopy fixing done
R-1	shifting done from cc-111 to cc-112
SCR-2, S-1	interchanging done
CC-44,33,SCR-4	PPM done