



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/07/2025

Area: CHP

Equipment	Job
LC 17	Room cleaning done
CC 32,SCR 5	PPM was done
CC 7	Running inspection defect rectified
SCR 5	Boom chute sensor kept in ckt
SCR 1	Stacking 30* limits ckt problems rectified and tested
R 1,S 3	Interchanged the yard machines