



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-66	ZSS acting	Fuse cap fallen in CJB.Fuse replaced and tested okay	23:20:00	23:35:00	
2	OHP	BRC on CO-8A	B/C not running	OLR acted due to jamming.Reset done	01:50:00	02:10:00	
3	OHP	CO-84	OLR acted	.Reset done	03:30:00	03:40:00	
4	OHP	RSCO-10A	ZSS acting	ZSS probe gap adjusted	04:30:00	04:45:00	
5	OHP	BRC on CO-30	LT not taking place	PCRD tension acted.Released and tested okay	05:20:00	05:35:00	
6	CHP	CC-223	Drive tripped	Reset done	23:05:00	23:51:00	
7	CHP	CC-216	CJD acted	Probe cleaned and tested okay	01:45:00	01:55:00	