



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/04/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 8A	BW 2 not running	Wrong complaint	06:45:00	07:05:00	
2	OHP	CO 33M	OLR acted	reset done	06:55:00	07:05:00	
3	OHP	CO 35	OLR acted	reset done	08:00:00	08:05:00	
4	OHP	VF 2A	Chute sensor not getting reset	Coupling and V belt damaged . Informed to Mechanical and operation	08:30:00	08:45:00	
5	OHP	BRC on CO 28	BW 2 not rotating	Fluid coupling and guide roller problem , informed to mechanical and operation	09:30:00	09:45:00	
6	OHP	BRC on CO 33M	Hydraulic pump not starting	Oil level low, informed to mechanical	10:30:00	11:00:00	
7	CHP	CC 33 , SCR 4	LT not working	PCRD motor OLR tripped , reset done	12:20:00	12:30:00	
8	CHP	CC 114	BRS bypassed	Operation requirement	09:00:00	09:08:00	again kept in circuit
9	CHP	CC 32 and CC 39	BRS in bypass condition	Kept in circuit as per operation request	12:00:00	12:25:00	
10	CHP	CC 131	Tripped	reset done, jamming in tail end. Informed operation	09:55:00	10:00:00	
11	CHP	CC 51	ZSS acted	due to coal jamming , informed to operation	13:15:00	13:20:00	